

MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)


(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2024/ 12061

Dated:- 15/10/24

It is certified that an inspection team headed by Sh. Vijay Kumar, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Gurukul Global School, Sector-13, Manimajra, Chandigarh, on 18.09.2024 and mentioned in inspection report that Gurukul Global School, Sector-13, Manimajra Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt.

The above Certificate is valid for a period of One year w.e.f 29.07.2024 (i.e. Water Sampling Date).


Medical Officer of Health
Municipal Corporation
Chandigarh.

To,
Gurukul Global School,
Sector-13, Manimajra,
Chandigarh.

Principal
Gurukul Global School
Sector - 13, Chandigarh

Managing Director
Gurukul Global School



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No. GGS/2024-25/167 dated 24.07.2024
Issued to :- The Accounts officer,
Gurukul Global School
Sector - 13, Chandigarh.
Quantity of sample :- Approximate 1200 ml.
Date of Collection :- 27-07-2024
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle
Source of sample :- from School tap of Gurukul Global School
Sector - 13, Manimajra, Chandigarh.


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.69
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	mg/l	0.7
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	124
7	Total Hardness (as CaCO ₃)	< 200	mg/l	90
8	Chloride (as Cl)	< 250	mg/l	06
9	Free & Saline Ammonia	Nil	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	156
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received vide receipt No.07/2024-25/204059, dated 25.07.2024, Amount Rs.3300/-

Note:- Water is fit for drinking

Lab No.- MCPHL/24/ 3201

Dated:- 29.07.2024


Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh


Enclst No. MCPH/24/.....

Dated :- 29.07.2024

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information and necessary action please.

Principal
Gurukul Global School
Sector - 13, Chandigarh


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh